

# Memo

**To:** City Council

**From:** Gary Hartwell

**CC:** Henry Hill

**Date:** December 7, 2009

**Re:** Monthly Report for November, 2009

We recorded 1.5 inches of rainfall in November and used 469.5 million gallons of water for the month. Our average usage was 15.7 million gallons per day (mgd) or about 141.7 gallons per person per day (gpcd). Our daily water usage ranged from a minimum of 10.2 mgd (95 gpcd) on November 6 to a maximum of 19.6 mgd (183 gpcd) on November 14. For the year, we have recorded about 39.2 inches of rainfall. The November bacteriological and disinfectant by-product samples all tested negative for contamination. All of our chlorine samples tested within the normal limits for water quality.

We installed about 114 water meters in November and we televised about 155 private service lines for new homes.

We inspected about 528 fire hydrants and about 127 manholes for proper operation. We repaired 21 sidewalks and installed about 32 traffic signs.

We used about 19,056 gallons of unleaded fuel and about 9,111 gallons of diesel fuel in the month of November.

We collected about 2,523 residential tons and about 2,876 tons of commercial solid waste in October. Curbside recycling was about 1,005 tons in October.